



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5146BQ0134

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	LOXEAL s.r.l. Via Marconato, 2, I-20031 Cesano Maderno (MI)
Distributor <i>Vertreiber</i>	LOXEAL s.r.l. Via Marconato, 2, I-20031 Cesano Maderno (MI)
Product Category <i>Produktart</i>	greasing and sealing materials: Sealing and jointing materials for screwed joint of gas appliances and gas plants, hardening (5146)
Product Description <i>Produktbezeichnung</i>	Anaerobic jointing compound, not permitted for the gas-installation according to DVGW-TRGI 2008
Model <i>Modell</i>	Luxeal 83-50
Test Reports <i>Prüfberichte</i>	laboratory control test: 14/169/5146/05 from 25.07.2014 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DIN EN 751-1 (01.05.1997)

Date of Expiry / File No. 01.03.2020 / 14-0864-GNV
Ablaufdatum / Aktenzeichen

25.02.2015 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type	Technical Data	Remarks
Typ	Technische Daten	Bemerkungen
Loxreal 83-50	class: H	for dimensions > DN 10 up to DN 50

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

Suitable for metallic joints with coarse threads

Not permitted for the gas-installation according to DVGW-TRGI 2008